

SHEHENDEHOWA CENTRAL SCHOL DISTRICT SAMPLING LOCATION / ID NUMBER

BUILDING: Arongen Elementary DATE: 2/17/17

CUSTODAIN: _____ CONTACT #: _____

BUILDING ADDRESS: 489, Clifton Park Center Rd, Clifton Park # OF SAMPLES: 122

<u>OUTLET TYPE</u>	<u>LOCATION</u>	<u>ID NUMBER</u>	<u>NOTES</u>	<u>RESULTS</u>	<u>RETEST</u>
bathroom sink	Main office	ARO-1		< 1.0	
Kitchen sink	Main office	ARO-2		< 1.0	
Custodial Closet sink	Main office	ARO-3	Locked - Non drinking source	X	
sink	Library	ARO-4		< 1.0	
Sink	kindergarten rm 101	ARO-5		2.5	
fountain	kindergarten rm 101	ARO-6		< 1.0	
sink	Kindergarten rm 102	ARO-7		< 1.0	
fountain	kindergarten rm 102	ARO-8		< 1.0	
sink	kindergarten rm 103	ARO-9		< 1.0	
fountain	kindergarten rm 103	ARO-10		< 1.0	
sink	kindergarten rm 104	ARO-11		< 1.0	
fountain	kindergarten rm 104	ARO-12		< 1.0	
sink	kindergarten rm 105	ARO-13		< 1.0	
fountain	kindergarten rm 105	ARO-14		< 1.0	
bathroom sink	kindergarten rm 105	ARO-15		5.3	
sink	kindergarten rm 106	ARO-16		< 1.0	
fountain	kindergarten rm 106	ARO-17		< 1.0	
sink	Nurse by rm 106	ARO-18		< 1.0	
Bathroom sink	Nurse by rm 106	ARO-19		270	<1
sink	nurse by rm 106	ARO-20	located in back of rm to right of windows	4.5	
sink	Drinking fountain rm 121	ARO-21		1.4	
Sink	room 107	ARO-22		< 1.0	
Fountain	room 107	ARO-23		1.1	

sink	room 108	ARO-24		< 1.0	
fountain	room108	ARO-25		< 1.0	
sink	room 109	ARO-26		< 1.0	
fountain	room 109	ARO-27		< 1.0	
sink	room 110	ARO-28		< 1.0	
fountain	room 110	ARO-29		< 1.0	
sink 1	boys bathroom	ARO-30	facing sink left sink #1 across from rm 108	< 1.0	
sink 2	boys bathroom	ARO-31	facing sink to right sink #2 across from rm 108	< 1.0	
sink 1	girls bathroom	ARO-32	facing sinks left sink #1 across from room 109	< 1.0	
sink 2	Girls bathroom	ARO-33	facing sink to right sink #2 Across from rm 109	< 1.0	
sink	Woman's bathroom	ARO-34	facing fountain in downstairs hall to the left	< 1.0	
sink	Men's Bathroom	ARO-35	facing fountain in downstairs hall to the left	< 1.0	
sink	custodial closet	ARO-36	Locked - Non drinking source	X	
Fountain	Hallway	ARO-37	End of hallway down stairs by J-closet and rm113	< 1.0	
sink	Music rm 122	ARO-38	starting from bus port side	< 1.0	
sink	Faculty	ARO-39	bus port end of hall	< 1.0	
men's bathroom sink	faculty	ARO-40	bus port end of hall	< 1.0	
Ladies bathroom sink	faculty	ARO-41	bus port end of hall	< 1.0	
sink	rm 121	ARO-42		< 1.0	
sink	rm 120	ARO-43		< 1.0	
fountain	rm 120	ARO-44		< 1.0	
bathroom sink	rm 119	ARO-45		< 1.0	
sink	rm 119	ARO-46		< 1.0	
fountain	rm 119	ARO-47		< 1.0	
sink	rm 118	ARO-48		< 1.0	
fountain	rm 118	ARO-49		< 1.0	
bathroom sink	rm 118	ARO-50		< 1.0	
sink	rm 116	ARO-51		< 1.0	
fountain	rm 116	ARO-52		< 1.0	
sink	rm 117	ARO-53		< 1.0	

fountain	rm 117	ARO-54		< 1.0	
sink	rm 115	ARO-55		< 1.0	
fountain	rm 115	ARO-56		< 1.0	
sink	rm 114	ARO-57		< 1.0	
fountain	rm 114	ARO-58		< 1.0	
sink #1	art rm 113	ARO-59	sink #1 back of room m facing sink far left # 1	< 1.0	
sink #2	art rm 113	ARO-60	sink #2 back of room facing sink to the right #2	< 1.0	
sink #3	art rm 113	ARO-61	sink #3 to the right of the door Facing sink to left #3	< 1.0	
sink#4	art rm 113	ARO-62	sink #4 to right of door facing sink to right #4	< 1.0	
fountain	hall by cafeteria	ARO-63	just outside cafeteria by bus port	< 1.0	
sink	dish washer room	ARO-64	inside cafeteria	2.3	
Sink	Kitchen Bathroom	ARO-65	Kitchen Bathroom #1 on map	< 1.0	
sink	Kitchen	ARO-66	right of office/left of cooler # 2 on map	< 1.0	
sink	Kitchen	ARO-67	Right of cooler # 3 on map	1.8	
sink	Kitchen	ARO-68	Right of storage rack # 4 on map	< 1.0	
sink	Kitchen	ARO-69	2nd sink toward caf. from storage rack #5 on map.	< 1.0	
Faucet	Kitchen	ARO-70	Kettle fill # 6 on map.	3.4	
Sink	Kitchen	ARO-71	Sink in center #7 on map.	< 1.0	
Hose	Kitchen	ARO-72	Filler hose # 8 on map	1.3	
sink	Kitchen	ARO-73	Sink # 9 on map	1.9	
Sink	Custodial Closet - Kitchen	ARO-74	Locked - Non drinking source	X	
Sink	Kitchen - outside walk-in cooler	ARO-75	sink #11 on map	< 1.0	
Hose	Kitchen	ARO-76	Non drinking source - Posted Non-Drinking	X	
sink	custodial closet	ARO-77	Locked - Non drinking source	X	
sink #1	girls bathroom	ARO-78	across from cafeteria facing sinks left sink is#1	< 1.0	
sink #2	girls bathroom	ARO-79	across from cafeteria facing sinks left sink is#2	< 1.0	
sink #1	boys bathroom	ARO-80	across from cafeteria facing sinks left sink is #1	< 1.0	
sink #2	boys bathroom	ARO-81	across from cafeteria facing sink right sink is#2	< 1.0	
Wash-down hose	receiving room	ARO-82	Posted Non drinking source	X	
sink	social worker	ARO-83	across from boiler room by salt tank	< 1.0	

sink	coach office	ARO-84	across from boiler rm. By salt tank	< 1.0	
sink	rm 223	ARO-85	starting at stairs second floor end by bus port	< 1.0	
fountain	rm223	ARO-86		1.7	
sink	rm221	ARO-87		< 1.0	
fountain	rm221	ARO-88		< 1.0	
sink	rm220	ARO-89		< 1.0	
fountain	rm220	ARO-90		< 1.0	
sink	rm219	ARO-91		< 1.0	
fountain	rm219	ARO-92		< 1.0	
sink	rm218	ARO-93		< 1.0	
fountain	rm218	ARO-94		< 1.0	
sink	rm217	ARO-95		< 1.0	
fountain	rm217	ARO-96		< 1.0	
sink	rm216	ARO-97		< 1.0	
fountain	rm216	ARO-98		< 1.0	
sink	rm 215	ARO-99		< 1.0	
fountain	rm215	ARO-100		< 1.0	
sink	rm214	ARO-101		< 1.0	
fountain	rm214	ARO-102		< 1.0	
sink	rm213	ARO-103		< 1.0	
fountain	rm213	ARO-104		< 1.0	
sink	rm212	ARO-105		< 1.0	
fountain	Art rm 113	ARO-106		< 1.0	
fountain	hall	ARO-107	end of hall by room 212	< 1.0	
sink	custodial closet	ARO-108	Locked - Non drinking source	X	
bath sink	woman's room	ARO-109	end of hall by room 212	< 1.0	
bath sink	men's room	ARO-110	end of hall by room 212	< 1.0	
sink	rm210	ARO-111		< 1.0	
fountain	rm210	ARO-112		< 1.0	
sink	rm209	ARO-113		< 1.0	

fountain	rm209	ARO-114		< 1.0	
sink	rm208	ARO-115		< 1.0	
fountain	rm208	ARO-116		< 1.0	
sink	rm207	ARO-117		< 1.0	
fountain	rm207	ARO-118		< 1.0	
sink #1	boys bathroom	ARO-119	across from rm 208 sink #1 facing sink left sink is #1	< 1.0	
sink#2	boys bathroom	ARO-120	across from rm 208 sink #2 facing sink right sink is #2	< 1.0	
sink#1	girls bathroom	ARO-121	across from rm 209 sink #1 facing sink left sink is #1	< 1.0	
sink#2	girls bathroom	ARO-122	across from rm 209 sink #2 facing sink right sink is #2	< 1.0	