

SHEHENDEHOWA CENTRAL SCHHOL DISTRICT SAMPLING LOCATION / ID NUMBER

BUILDING: Chango Elementary DATE: 2/17/17

CUSTODAIN: _____ CONTACT #: _____

BUILDING ADDRESS: 100 Chango Drive, Ballston Lake, NY 12019 # OF SAMPLES: 84

<u>OUTLET TYPE</u>	<u>LOCATION</u>	<u>ID NUMBER</u>	<u>NOTES</u>	<u>RESULTS</u>	<u>RETEST</u>
Sink	#1 in hall by exit 5	CHA-1	1st closest to exit 5	< 1.0	
Sink	#2 in hall by exit 5	CHA-2	2nd closest to exit 5	< 1.0	
Sink	#3 in hall by exit 5	CHA-3	3rd furthest from exit 5	< 1.0	
Sink	#4 in hall by exit 5	CHA-4	4th furthest from exit 5	< 1.0	
Sink	Room 1	CHA-5		3.9	
Water fountain	Room 1	CHA-6		2.7	
Sink	Room 2	CHA-7		3.5	
Water fountain	Room 2	CHA-8		1.2	
Sink	Room 3	CHA-9	Higher sink	2.8	
Sink	Room 3	CHA-10	Lower sink	4.3	
Water fountain	Room 3	CHA-11		4.3	
Foot operated sink	Across from room 7	CHA-12		< 1.0	
Water fountain	Room 4	CHA-13		1.7	
Water fountain	Room 5	CHA-14	Higher fountain	< 1.0	
Water fountain	Room 5	CHA-15	Lower fountain	< 1.0	
Sink	Room 5	CHA-16		< 1.0	
Water fountain	Room 6	CHA-17	Higher fountain	< 1.0	
Water fountain	Room 6	CHA-18	Lower fountain	< 1.0	
Sink	Room 6	CHA-19		1.1	
Sink	Room 7	CHA-20		1.5	
Water fountain	Room 7	CHA-21		< 1.0	
Sink	Room 8	CHA-22		25.0	<1.0
Water fountain	Room 8	CHA-23		6.1	

Sink	Room 9	CHA-24		3.5	
Water fountain	Room 9	CHA-25		1.3	
Sink	Room 10	CHA-26		1.8	
Water fountain	Room 10	CHA-27		1.3	
Sink	Room 11	CHA-28	Sink to left as you face windows	3.1	
Sink	Room 11	CHA-29	right facing windows (by AC unit)	< 1.0	
Sink	Room 12/13	CHA-30		6.3	
Water fountain	Room 12/13	CHA-31		< 1.0	
Sink	Room 14	CHA-32		2.4	
Water fountain	Room 14	CHA-33		< 1.0	
Foot operated sink	Across from room 11	CHA-34		3.0	
Sink	Woman's room by room 15	CHA-35		1.7	
Sink	Room 15	CHA-36		1.5	
Water fountain	Room 15	CHA-37		2.5	
Water fountain	Cafeteria	CHA-38		< 1.0	
Sink	Nurses office	CHA-39	Replaced Faucet	14.0	<1.0
Sink	Nurses office bathroom	CHA-40		< 1.0	
Sink	A-6	CHA-41		330.0	<1.0
Sink	A-5	CHA-42		16.0	<1.0
Sink	Men's room by gym/Main office	CHA-43		< 1.0	
Water fountain	Hall by gym/main office	CHA-44		< 1.0	
Sink	Woman's room by gym/main office	CHA-45		< 1.0	
Sink	Handicap bathroom by gym/main office	CHA-46		< 1.0	
Sink	Staff bathroom by dock/music room	CHA-47		1.1	
Sink	Faculty room	CHA-48		2.3	
Sink	Kitchen by milk cooler	CHA-49		11.0	
Sink	Kitchen by dishwasher	CHA-50	Double sink	6.3	
Sink	Kitchen by dishwasher	CHA-51	Single sink in corner	7.5	
Sink	Kitchen by dishwasher	CHA-52	Sprayer wash sink	11.0	
Foot operated sink	Across from room 20	CHA-53		< 1.0	

Water fountain	Room 17	CHA-54		5.0	
Sink	Room 17	CHA-55		2.8	
Water fountain	Room 18	CHA-56	Higher fountain	< 1.0	
Water fountain	Room 18	CHA-57	Lower fountain	< 1.0	
Sink	Room 18	CHA-58		1.3	
Water fountain	Room 19	CHA-59	Higher fountain	< 1.0	
Water fountain	Room 19	CHA-60	Lower fountain	< 1.0	
Sink	Room 19	CHA-61		1.6	
Water fountain	Room 20	CHA-62		4.1	
Sink	Room 20	CHA-63		3.5	
Water Fountain	Room 21	CHA-64		9.9	
Sink	Room 22	CHA-65		4.7	
Water Fountain	Room 22	CHA-66		6.7	
Sink	Room 23	CHA-67		3.2	
Water Fountain	Room 23	CHA-68		4.3	
Foot operated sink	Across from room 24	CHA-69		3.9	
Sink	Room 24	CHA-70		6.7	
Water Fountain	Room 24	CHA-71		9.0	
Water Fountain	Room 29	CHA-72		< 1.0	
Sink	Room 29 bathroom	CHA-73		< 1.0	
Water Fountain	Room 30	CHA-74		< 1.0	
Sink	Room 30 bathroom	CHA-75		< 1.0	
Sink	Room 25/26	CHA-76		1.8	
Water Fountain	Room 25/26	CHA-77		2.1	
Sink	Room 27/28	CHA-78		4.7	
Water Fountain	Room 27/28	CHA-79		3.4	
Sink	Bathroom by room 28	CHA-80		1.5	
Sink	Library office	CHA-81		9.5	
Sink	B-1 Aides room off of library	CHA-82		1.9	
Sink	Men's room in library	CHA-82		< 1.0	

Wash-down hose	Dock	CHA-83		6.9	
Sink	Boiler Rm.	CHA-84		1.3	

EXAMPLES:

Outlet Type: Sink Faucet, drinking Fountain, Sink Bubbler, Ice Machine, Plumbed Coffee maker

Location: Classroom #, Kitchen, Boys restroom, Girls restroom, Lobby, Nurses office, Hall/Near Room, Break room