SHEHENDEHOWA CENTRAL SCHHOL DISTRICT SAMPLING LOCATION / ID NUMBER

| BUILDING: | HIGH SCHOOL EAST | DATE: | 2/17/17 |
|------------------|------------------------------------|---------------|---------|
| CUSTODAIN: | | CONTACT #: | |
| BUILDING ADDRESS | 940 RT 149 CLIFTON PARK N,Y, 12065 | # OF SAMPLES: | 311/92 |

| OUTLET TYPE | LOCATION | ID NUMBER | NOTES | <u>RESULTS</u> | <u>RETEST</u> |
|-------------|------------------------------------|-----------|-----------------------------|----------------|---------------|
| Sink Faucet | MAIN OFFICE bathroom | HSE-01 | 1-Faucet | 1.1 | |
| Sink Faucet | NURSES OFFICE BATHROOM | HSE-02 | 1-Faucet | 9.2 | |
| Sink Faucet | Nurses Office - Main Area | HSE-03 | 1-Faucet | 9.2 | |
| Sink Faucet | NURSES BACK ROOM ON COUNTER | HSE-04 | 1-Faucet | 10.2 | |
| Sink Faucet | North Faculty Kitchen - 102 | HSE-05 | | 1.3 | |
| Sink Faucet | North Faculty Men's Rm - 102 | HSE-06 | | 0.72 | |
| Sink Faucet | North Faculty Ladies rm 102 | HSE-07 | | 2.3 | |
| Sink Faucet | LADIES ROOM AA OFFICE | HSE-08 | Sink # 1 on right side | 1.7 | |
| Sink Faucet | LADIES ROOM AA OFFICE | HSE-09 | Sink # 2 on left side | 2.2 | |
| Sink Faucet | MENS ROOM AA OFFICE | HSE-10 | 1 SINK & FAUCET | 2.0 | |
| Sink Faucet | GIRLS ROOM NEAR 107 | HSE-11 | Faucet #1 - Map 107 | 3.0 | |
| Sink Faucet | GIRLS ROOM NEAR 107 | HSE-12 | faucet #2 - Map 107 | 2.0 | |
| Sink Faucet | GIRLS ROOM NEAR 107 | HSE-13 | Faucet #3 - Map 107 | 2.5 | |
| Sink Faucet | GIRLS ROOM NEAR 107 | HSE-14 | Faucet #4 - Map 107 | 1.7 | |
| Sink Faucet | C-107 Classroom | HSE-15 | 1st sink near door | 9.6 | |
| Sink Faucet | C-107 Classroom | HSE-16 | 2nd sink furthest from door | 1.9 | |
| Sink Faucet | LIBRARY Kitchen | HSE-17 | Faucet | 3.3 | |
| Sink Faucet | Ramp Handicap Bathroom by Stair #3 | HSE-18 | | 3.6 | |
| Sink Faucet | ART ROOM 110 | HSE-19 | Faucet #1 - Map A110 | 4.8 | |
| Sink Faucet | ART ROOM 110 | HSE-20 | Faucet #2 - Map A110 | 2.8 | |
| Sink Faucet | ART ROOM 110 | HSE-21 | Faucet #3 - Map A110 | 4.4 | |
| Sink Faucet | ART ROOM 110 | HSE-22 | Faucet #4 - Map A110 | 6.7 | |
| Sink Faucet | ART ROOM 110 | HSE-23 | Faucet #5 - Map A110 | 18.3 | <1 |

| Sink Faucet | ART ROOM 110 | HSE-24 | Faucet #6 -Map A110 | 18.2 | <1 |
|-------------|------------------------------------|--------|---|------|------|
| Sink Faucet | ART ROOM 111 ART OFFICE Sink | HSE-25 | on right | 7.1 | |
| Sink Faucet | ART ROOM 112 | HSE-26 | 1st faucet closest to door | 6.7 | |
| Sink Faucet | ART ROOM 112 | HSE-27 | 2nd faucet furthest from door. | 0.86 | |
| Sink Faucet | ART ROOM 113 | HSE-28 | Faucet #1 closest to door | 2.9 | |
| Sink Faucet | ART ROOM 113 | HSE-29 | Faucet #2 in middle | 5.2 | |
| Sink Faucet | ART ROOM 113 | HSE-30 | Faucet #3 furthest from door | 8.5 | |
| Sink Faucet | ART ROOM 114 | HSE-31 | 1st faucet closest to door | 2.2 | |
| Sink Faucet | ART ROOM 114 | HSE-32 | 2nd faucet furthest from door. | 1.7 | |
| Sink Faucet | ART ROOM 115 | HSE-33 | Faucet #1 - Map 115 | 12.8 | |
| Sink Faucet | ART ROOM 115 | HSE-34 | Faucet #2 - Map 115 | 13.1 | |
| Sink Faucet | ART ROOM 115 | HSE-35 | Faucet #3 - Map 115 | 19.0 | <1 |
| Sink Faucet | Art Room 115 - Dark Room | HSE-36 | Faucet # 1 - Map 115 Dark Room | 19.1 | POST |
| Sink Faucet | Art Room 115 - Dark Room | HSE-37 | Faucet # 2 - Map 115 Dark Room | 134 | POST |
| Sink Faucet | ART ROOM 116 | HSE-38 | Faucet #1 - Map 116 | 4.6 | |
| Sink Faucet | ART ROOM 116 | HSE-39 | faucet #2 - Map 116 | 1.5 | |
| Sink Faucet | ART ROOM 116 | HSE-40 | Faucet #3 - Map 116 | 1.6 | |
| Sink Faucet | BOYS ROOM NEAR 118 | HSE-41 | Faucet # 1- Looking at sink - Left Sink | 1.8 | |
| Sink Faucet | BOYS ROOM NEAR 118 | HSE-42 | Faucet # 2- Looking at sink - middle Sink | 0.54 | |
| Sink Faucet | BOYS ROOM NEAR 118 | HSE-43 | Faucet # 1- Looking at sink - Right Sink | 3.3 | |
| Sink Faucet | SOUTH FACULITY ROOM MENS RM B122 | HSE-44 | 1-Faucet | 3.3 | |
| Sink Faucet | SOUTH FACULITY ROOM LADIES RM B122 | HSE-45 | 1-Faucet | 3.9 | |
| Sink Faucet | SOUTH FACULTY ROOM KITCHEN | HSE-46 | 1-Faucet | 1.2 | |
| Sink Faucet | Grils Room near 125 | HSE-47 | Faucet #1 - map - Girls rm near 125 | 1.2 | |
| Sink Faucet | Girls Room near 125 | HSE-48 | faucet #2 - map - Girls rm near 125 | 3.1 | |
| Sink Faucet | Girls Room near 125 | HSE-49 | Faucet #3 - map - Girls rm near 125 | 17.8 | <1 |
| Sink Faucet | Girls Room near 125 | HSE-50 | Faucet #4 - map - Girls rm near 125 | 5.3 | |
| Sink Faucet | FRIDGE AREA NEXT TO DOCK | HSE-51 | 1-Faucet | 3.7 | |
| Sink Faucet | WELLNESS CENTER MENS BATHROOM | HSE-52 | 1-Faucet | 2.9 | |
| Sink Faucet | WELLNESS CENTER LADIES BATHROOM | HSE-53 | 1-Faucet | 1.8 | |

| Sink Faucet | Wellness Center | HSE-54 | 1-Faucet | 3.5 | |
|-------------|-------------------------------|--------|---|------|------|
| Sink Faucet | DOCK AREA BATHROOM | HSE-55 | 1-Faucet | 0.27 | |
| Sink Faucet | DOCK AREA BREAKROOM | HSE-56 | 1-Faucet | 0.87 | |
| Sink Faucet | KITCHEN | HSE-57 | Faucet #1 - map | 4.4 | |
| Sink Faucet | KITCHEN | HSE-58 | faucet #2 - map - Not in service | Х | |
| Sink Faucet | KITCHEN | HSE-59 | Faucet #3 - map | 4.0 | |
| Sink Faucet | KITCHEN | HSE-60 | Faucet #4 - map | 6.5 | |
| Sink Faucet | KITCHEN | HSE-61 | Faucet #5 - map | 4.9 | |
| Sink Faucet | KITCHEN | HSE-62 | Faucet #6 - map | 1.9 | |
| Sink Faucet | KITCHEN | HSE-63 | Faucet Sprayer - map | 1.0 | |
| Sink Faucet | KITCHEN | HSE-64 | Bathroom Sink | 3.0 | |
| Sink Faucet | Kitchen - Ladies room | HSE-65 | | 6.7 | |
| Sink Faucet | STAFF FACULITY - Near kitchen | HSE-66 | SINK AND FAUCET | 5.3 | |
| Sink Faucet | Green House | HSE-67 | Sink #1 | 9.1 | |
| Sink Faucet | 128 WOOD SHOP | HSE-68 | Sink #1 - Looking at sink - Left Sink | 2.7 | |
| Sink Faucet | 128 WOOD SHOP | HSE-69 | Sink #1 - Looking at sink - Middle Sink | 1.4 | |
| Sink Faucet | 128 WOOD SHOP | HSE-70 | Sink #1 - Looking at sink - Right Sink | 9.6 | |
| Sink Faucet | BOYS ROOM NEAR 130 | HSE-71 | Faucet #1 - Map 130 | 3.4 | |
| Sink Faucet | BOYS ROOM NEAR 130 | HSE-72 | Faucet #2 - Map 130 | 1.9 | |
| Sink Faucet | BOYS ROOM NEAR 130 | HSE-73 | Faucet #3 - Map 130 | 3.7 | |
| Sink Faucet | BOYS ROOM NEAR 130 | HSE-74 | Faucet #4 - Map 130 | 6.8 | |
| Sink Faucet | 134 TECH ROOM | HSE-75 | Sink #1 - Looking at sink - Left Sink | 3.4 | |
| Sink Faucet | 134 TECH ROOM | HSE-76 | Sink #1 - Looking at sink - Middle Sink | 9.3 | |
| Sink Faucet | 134 TECH ROOM | HSE-77 | Sink #1 - Right Sink Not in Service | Х | |
| Sink Faucet | 135 AUTOMOTIVE | HSE-78 | Sink #1 - Looking at sink - Left Sink | 40.1 | POST |
| Sink Faucet | 135 AUTOMOTIVE | HSE-79 | Sink #1 - Looking at sink - Middle Sink | 3.8 | |
| Sink Faucet | 135 AUTOMOTIVE | HSE-80 | Sink #1 - Looking at sink - Right Sink | 12.5 | |
| Sink Faucet | 136 Robotics | HSE-81 | Faucet # 1 Left side of sink | 1.6 | |
| Sink Faucet | 136 Robotics | HSE-82 | Faucet # 2 Right side of sink | 5.9 | |
| Sink Faucet | SCIENCE ROOM 126 | HSE-83 | Faucet #1 - Map 126 | 120 | POST |

| Sink Faucet | SCIENCE ROOM 126 | HSE-84 | Faucet #2 - Map 126 | 9.3 | |
|-------------|------------------------------------|---------|---|------|------|
| Sink Faucet | SCIENCE ROOM 126 | HSE-85 | Faucet #3 - Map 126 | 5.6 | |
| Sink Faucet | SCIENCE ROOM 126 | HSE-86 | Faucet #4 - Map 126 | 6.2 | |
| Sink Faucet | SCIENCE ROOM 126 | HSE-87 | Faucet #5 - Map 126 | 10.2 | |
| Sink Faucet | SCIENCE ROOM 126 | HSE-88 | Faucet #6 - Map 126 | 22.4 | POST |
| Sink Faucet | Prep Room - 126/127 | HSE-89 | Faucet on 126 rm. Side | 19.6 | POST |
| Sink Faucet | Prep Room - 126/127 | HSE-90 | Faucet on 127 rm. Side | 11.9 | |
| Sink Faucet | SCIENCE ROOM 127 | HSE-91 | Faucet #1 - Map 127 | 5.1 | |
| Sink Faucet | SCIENCE ROOM 127 | HSE-92 | Faucet #2 - Map 127 | 7.5 | |
| Sink Faucet | SCIENCE ROOM 127 | HSE-93 | Faucet #3 - Map 127 | 62.7 | POST |
| Sink Faucet | SCIENCE ROOM 127 | HSE-94 | Faucet #4 - Map 127 | 10.5 | |
| Sink Faucet | SCIENCE ROOM 127 | HSE-95 | Faucet #5 - Map 127 | 10.3 | |
| Sink Faucet | SCIENCE ROOM 127 | HSE-96 | Faucet #6 - Map 127 | 7.3 | |
| Sink Faucet | GUIDENCE OFFICE - Counseling | HSE-97 | Bathroom Faucet | 0.7 | |
| Sink Faucet | GIRLS ROOM MAIN HALL | HSE-98 | Bradley | 1.0 | |
| Sink Faucet | BOYS ROOM MAIN HALL | HSE-99 | Bradley | 2.2 | |
| Sink Faucet | BOYS LOCKER ROOM - Main Gym | HSE-100 | Sink right side #1 | 1.1 | |
| Sink Faucet | BOYS LOCKER ROOM - Main Gym | HSE-101 | Sink Middle #2 | 0.79 | |
| Sink Faucet | BOYS LOCKER ROOM - Main Gym | SKIP | Sink Left side #3 - No spout - Not in Service | Х | |
| Sink Faucet | BOYS COACHES OFFICE - Main Gym | HSE-102 | 1-Faucet | 10.2 | |
| Sink Faucet | OLD COACHES OFFICE | HSE-103 | 1-Faucet | 9.6 | |
| Sink Faucet | SATELLITE Cafe KITCHEN | HSE-104 | SINK AND FAUCET HAND WASHING | 4.2 | |
| Sink Faucet | ATH DIRECTOR | HSE-105 | 1-Faucet | 1.5 | |
| Sink Faucet | GIRLS PE COACHES OFFICE - Main Gym | HSE-106 | 1-Faucet | 6.4 | |
| Sink Faucet | GIRLS LOCKER ROOM - Main Gym | HSE-107 | Faucet #1 - Girls Locker room map | 2.8 | |
| Sink Faucet | GIRLS LOCKER ROOM - Main Gym | HSE-108 | Faucet #2 - Girls Locker room map | 2.4 | |
| Sink Faucet | GIRLS LOCKER ROOM - Main Gym | HSE-109 | Faucet #3 - Girls Locker room map | 2.1 | |
| Sink Faucet | GIRLS LOCKER ROOM - Main Gym | HSE-110 | Faucet #4 - Girls Locker room map | 3.1 | |
| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-111 | Faucet # 1 - Boys Gang - West Wing Map | 1.0 | |
| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-112 | Faucet # 2 - Boys Gang - West Wing Map | 0.91 | |

| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-113 | Faucet # 3 - Boys Gang - West Wing Map | 1.1 | |
|-------------|-------------------------------|---------|--|------|------|
| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-114 | Faucet # 4 - Boys Gang - West Wing Map | 3.8 | |
| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-115 | Faucet # 5 - Boys Gang - West Wing Map | 4.0 | |
| Sink Faucet | BOYS GANG BATHROOM WEST WING | HSE-116 | Faucet # 6 - Boys Gang - West Wing Map | 6.8 | |
| Sink Faucet | Staff Bathroom near 139 | HSE-117 | 1-Faucet | 3.0 | |
| Sink Faucet | Girls Rm. Near 141 | HSE-118 | Sink #1 - Looking at sink - Left Sink | 2.8 | |
| Sink Faucet | Girls Rm. Near 141 | HSE-119 | Sink #1 - Looking at sink - Middle Sink | 2.5 | |
| Sink Faucet | Girls Rm. Near 141 | HSE-120 | Sink #1 - Looking at sink - Right Sink | 2.4 | |
| Sink Faucet | SCIENCE ROOM142 | HSE-121 | 1-Faucet Teachers work station sink | 25.2 | POST |
| Sink Faucet | 142/143 Prep room | HSE-122 | See 142/143 Prep Room Map. | 48.9 | POST |
| Sink Faucet | 142/143 Prep room | HSE-123 | See 142/143 Prep Room Map. | 56.5 | POST |
| Sink Faucet | 142/143 Prep room | HSE-124 | See 142/143 Prep Room Map. | 34.2 | POST |
| Sink Faucet | SCIENCE ROOM 143 | HSE-125 | 1-Faucet Teachers work station sink | 18.7 | POST |
| Sink Faucet | SCIENCE ROOM 144 | HSE-126 | 1-Faucet Teachers work station sink | 26.3 | POST |
| Sink Faucet | SCIENCE ROOM 145 | HSE-127 | 1-Faucet Teachers work station sink | 14.2 | |
| Sink Faucet | 145/147 Prep room | HSE-128 | See 145/147 Prep Room Map. | 18.4 | POST |
| Sink Faucet | SCIENCE ROOM 146 | HSE-129 | 1-Faucet Teachers work station sink | 849 | POST |
| Sink Faucet | SCIENCE ROOM 147 | HSE-130 | 1-Faucet Teachers work station sink | 83.4 | POST |
| Sink Faucet | SCIENCE ROOM 148 | HSE-131 | 1-Faucet | 22.2 | POST |
| Sink Faucet | 148/149 Prep room | HSE-132 | See 148/149 Prep Room Map. | 91.4 | POST |
| Sink Faucet | SCIENCE ROOM 149 | HSE-133 | 1-Faucet | 3.8 | |
| Sink Faucet | Room 150 | HSE-134 | Sink #1 - Looking at sink - Left Sink | 1.1 | |
| Sink Faucet | Room 150 | HSE-135 | Sink #1 - Middle - Not in Service | Х | |
| Sink Faucet | Room 150 | HSE-136 | Sink #1 - Looking at sink - Right Sink | 1.6 | |
| Sink Faucet | FACULITY BATHROOM NEAR 153 | HSE-137 | 1-Faucet | 0.6 | |
| Sink Faucet | FACULITY BATHROOM NEAR 154 | HSE-138 | 1-Faucet | 1.3 | |
| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-139 | Faucet # 1 - Girls Gang - West Wing Map Not in S | Х | |
| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-140 | Faucet # 2 - Girls Gang - West Wing Map | 3.2 | |
| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-141 | Faucet # 3 - Girls Gang - West Wing Map Not in S | Х | |
| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-142 | Faucet # 4 - Girls Gang - West Wing Map | 0.59 | |
| | | | | | |

| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-143 | Faucet # 5 - Girls Gang - West Wing Map | 1.2 | |
|-------------|--|-----------|---|------|-----|
| Sink Faucet | Girls GANG BATHROOM WEST WING | HSE-144 | Faucet # 6 - Girls Gang - West Wing Map | 1.7 | |
| Sink Faucet | BOYS LOCKER ROOM-New Gym- West wing | HSE-145 | Left sink #1 | 1.3 | |
| Sink Faucet | BOYS LOCKER ROOM-New Gym- West wing | HSE-146 | Middle Sink #2 | 2.8 | |
| Sink Faucet | BOYS LOCKER ROOM-New Gym- West wing | HSE-147 | Right Sink #3 | 2.7 | |
| Sink Faucet | BOYS LOCKER ROOM-New Gym- West wing | HSE-147-B | Far Right Sink #4 | 2.7 | |
| Sink Faucet | COACHES OFFICE - New Gym - West Wing | HSE-148 | 1-Faucet | 3.3 | |
| Sink Faucet | Officials Changing Bathroom- West Wing | HSE-149 | 1-Faucet | 0.35 | |
| Sink Faucet | Team Room | HSE-150 | 1-Faucet | 1.4 | |
| Sink Faucet | Trainers Rm. | HSE-151 | 1-Faucet | 0.4 | |
| ICE MACHINE | Trainers Rm. | HSE-152 | | 1.4 | |
| Sink Faucet | Girls Locker room - NEW GYM | HSE-153 | Faucet #1 - New Gym - Girls Locker Rm map | 1.2 | |
| Sink Faucet | Girls Locker room - NEW GYM | HSE-154 | Faucet #1 - New Gym - Girls Locker Rm map | 1.2 | |
| Sink Faucet | Girls Locker room - NEW GYM | HSE-155 | Faucet #1 - New Gym - Girls Locker Rm map | 1.4 | |
| Sink Faucet | Girls Locker room - NEW GYM | HSE-156 | Faucet #1 - New Gym - Girls Locker Rm map | 0.75 | |
| Sink Faucet | Girls Locker room - NEW GYM | HSE-157 | Faucet #1 - New Gym - Girls Locker Rm map | 1.3 | |
| Sink Faucet | GIRLS COACHES Bathroom - New Gym | HSE-158 | 1-Faucet | 11.7 | |
| Sink Faucet | Girls Officials Changing Rm Bathroom | HSE-159 | 1-Faucet | 1.6 | |
| Sink Faucet | DRESSING ROOM GIRLS - Auditorium | HSE-160 | Sink # 1 on right side | 25.2 | <1 |
| Sink Faucet | DRESSING ROOM GIRLS - Auditorium | HSE-161 | Sink # 2 on left side | 16.2 | 2.0 |
| Sink Faucet | DRESSING ROOM BOYS - Auditorium | HSE-162 | Sink # 1 on right side | 10.0 | |
| Sink Faucet | DRESSING ROOM BOYS - Auditorium | HSE-163 | Sink # 2 on left side | 5.7 | |
| 2ND FLOOR | | | | | |
| Sink Faucet | BOYS ROOM NEAR 203 | HSE-164 | Right hand sink #1 | 3.1 | |
| Sink Faucet | BOYS ROOM NEAR 203 | HSE-165 | Middle Sink #2 | 2.6 | |
| Sink Faucet | BOYS ROOM NEAR 203 | HSE-166 | Left Sink #3 | 3.9 | |
| Sink Faucet | GIRLS ROOM NEAR 207 | HSE-167 | Starting closest to door Faucet #1 | 2.6 | |
| Sink Faucet | GIRLS ROOM NEAR 207 | HSE-168 | Starting closest to door Faucet #2 | 3.5 | |
| Sink Faucet | GIRLS ROOM NEAR 207 | HSE-169 | Starting closest to door Faucet #3 | 2.9 | |
| Sink Faucet | GIRLS ROOM NEAR 207 | HSE-170 | Faucet #4 - Furthest from door | 1.5 | |

| Sink Faucet | Science 209 | HSE-171 | Faucet #1 closest to door | 9.9 | |
|-------------|--------------------|----------|--|--------|------|
| Sink Faucet | Science 209 | HSE-172 | Faucet #2 Furthest from door | 27.3 | POST |
| Sink Faucet | Science 210 - Prep | HSE-173 | Faucet on right side of door closest to door | 8.3 | |
| Sink Faucet | Science 210 - Prep | HSE-174 | Faucet on right side Furthest from door | 75.0 | POST |
| Sink Faucet | Science 210 - Prep | HSE-175 | Faucet on left side of door | 15.5 | POST |
| Sink Faucet | Science 211 | HSE-176 | Faucet #1 - map - Science 211 - Work Station | 10.9 | |
| Sink Faucet | Science 211 | HSE-177 | Faucet #2 - map - Science 211 | 22.6 | POST |
| Sink Faucet | Science 211 | HSE-178 | Faucet #3 - map - Science 211 | 22.8 | POST |
| Sink Faucet | Science 211 | HSE-179 | Faucet #4 - map - Science 211 | 23.3 | POST |
| Sink Faucet | Science 211 | HSE-180 | Faucet #5 - map - Science 211 | 34.8 | POST |
| Sink Faucet | Science 211 | HSE-181 | Faucet #6 - map - Science 211 | 16.2 | POST |
| Sink Faucet | Science 212 | HSE-182 | 1-Faucet - teachers work station | 17.5 | POST |
| Sink Faucet | Science room 212 | HSE-182A | (see map) Science 212 | 9.8 | |
| Sink Faucet | Science room 212 | HSE-182B | (see map) Science 212 | 108.0 | POST |
| Sink Faucet | Science room 212 | HSE-182C | (see map) Science 212 | 236.0 | POST |
| Sink Faucet | Science room 212 | HSE-182D | (see map) Science 212 | 17.5 | POST |
| Sink Faucet | Science room 212 | HSE-182E | (see map) Science 212 | 16.5 | POST |
| Sink Faucet | Science room 212 | HSE-182F | (see map) Science 212 | 7.1 | |
| Sink Faucet | Science room 212 | HSE-182G | (see map) Science 212 | 225.0 | POST |
| Sink Faucet | Science room 212 | HSE-182H | (see map) Science 212 | 28.0 | POST |
| Sink Faucet | Science room 212 | HSE-182I | (see map) Science 212 | 8.0 | |
| Sink Faucet | Science room 212 | HSE-182J | (see map) Science 212 | 6.9 | |
| Sink Faucet | Science room 212 | HSE-182K | (see map) Science 212 | 21.0 | POST |
| Sink Faucet | Science room 212 | HSE-182L | (see map) Science 212 | 2080.0 | POST |
| Sink Faucet | Science room 212 | HSE-182M | (see map) Science 212 | 481.0 | POST |
| Sink Faucet | Science room 212 | HSE-182N | (see map) Science 212 | 3950.0 | POST |
| Sink Faucet | Science room 212 | HSE-1820 | (see map) Science 212 | 1410.0 | POST |
| Sink Faucet | Science Room 213 | HSE-183 | Faucet #1 on right closest to door | 56.9 | POST |
| Sink Faucet | Science Room 213 | HSE-184 | Faucet #2 on right furthest from door | 38.4 | POST |
| Sink Faucet | Science Room 213 | HSE-185 | Faucet #1 on left closest to door | 20.9 | POST |

| Sink Faucet | Science Room 213 | HSE-186 | Faucet #2 on left furthest - Out of Service | Х | |
|-------------|------------------|----------|---|-------|------|
| Sink Faucet | Science room 214 | HSE-187A | (see map) Science 214 - Work Station | 20.9 | POST |
| Sink Faucet | Science room 214 | HSE-187B | (see map) Science 214 - Work Station | 25.4 | POST |
| Sink Faucet | Science room 214 | HSE-187C | (see map) Science 214 | 19.6 | POST |
| Sink Faucet | Science room 214 | HSE-187D | (see map) Science 214 | 5.6 | |
| Sink Faucet | Science room 214 | HSE-187E | (see map) Science 214 | 7.5 | |
| Sink Faucet | Science room 214 | HSE-187F | (see map) Science 214 | 26.7 | POST |
| Sink Faucet | Science room 214 | HSE-187G | (see map) Science 214 | 6.3 | |
| Sink Faucet | Science room 214 | HSE-187H | (see map) Science 214 | 4.2 | |
| Sink Faucet | Science room 214 | HSE-187I | (see map) Science 214 | 17.5 | POST |
| Sink Faucet | Science room 214 | HSE-187J | (see map) Science 214 | 5.2 | |
| Sink Faucet | Science room 214 | HSE-187K | (see map) Science 214 | 11.6 | |
| Sink Faucet | Science room 214 | HSE-187L | (see map) Science 214 | 4.0 | |
| Sink Faucet | Science room 214 | HSE-187M | (see map) Science 214 | 189.0 | POST |
| Sink Faucet | Science room 214 | HSE-187N | (see map) Science 214 | 96.8 | POST |
| Sink Faucet | Science room 214 | HSE-1870 | (see map) Science 214 | 20.9 | POST |
| Sink Faucet | Science room 214 | HSE-187P | (see map) Science 214 | 13.6 | |
| Sink Faucet | Science room 214 | HSE-187Q | (see map) Science 214 | 13.3 | |
| Sink Faucet | Science room 214 | HSE-187R | (see map) Science 214 | 81.6 | POST |
| Sink Faucet | Science room 215 | HSE-188A | (see map) Science 215 -Work Station | 27.8 | POST |
| Sink Faucet | Science room 215 | HSE-188B | (see map) Science 215 - Work Station | 19.2 | POST |
| Sink Faucet | Science room 215 | HSE-188C | (see map) Science 215 | 16.9 | POST |
| Sink Faucet | Science room 215 | HSE-188D | (see map) Science 215 | 11.5 | |
| Sink Faucet | Science room 215 | HSE-188E | (see map) Science 215 | 27.3 | POST |
| Sink Faucet | Science room 215 | HSE-188F | (see map) Science 215 | 12.8 | |
| Sink Faucet | Science room 215 | HSE-188G | (see map) Science 215 | 17.8 | POST |
| Sink Faucet | Science room 215 | HSE-188H | (see map) Science 215 | 22.2 | POST |
| Sink Faucet | Science room 215 | HSE-188I | (see map) Science 215 | 288.0 | POST |
| Sink Faucet | Science room 215 | HSE-188J | (see map) Science 215 | 62.4 | POST |
| Sink Faucet | Science room 215 | HSE-188K | (see map) Science 215 | 31.5 | POST |

| cience room 215 | HSE-188L | (see map) Science 215 | 70.4 | POST |
|-------------------------------|---|--|--|---|
| cience room 215 | HSE-188M | (see map) Science 215 | 47.7 | POST |
| cience room 215 | HSE-188N | (see map) Science 215 | 53.8 | POST |
| cience room 215 | HSE-1880 | (see map) Science 215 | 10.0 | |
| cience room 215 | HSE-188P | (see map) Science 215 | 11.9 | |
| rep rm. Between 215/217 | HSE-189 | 1-Faucet on right | 20.8 | POST |
| rep rm. Between 215/217 | HSE-190 | 1-Faucet on left - Not in Service | Х | |
| cience room 217 | HSE-191 | Faucet #1 - See Map 217 | 15.1 | POST |
| cience room 217 | HSE-192A | Faucet # 2 - See Map 217 | 13.9 | |
| cience room 217 | HSE-192B | Faucet # 5 - See map 217 - Teachers Work Statior | 14.4 | |
| cience room 217 | HSE-193 | Faucet #3 - See Map 217 | 22.3 | POST |
| cience room 217 | HSE-194 | Faucet #4- See Map 217 | 8.6 | |
| cience room 218 | HSE-195 | Faucet #1 - See Map 218 | 31.7 | POST |
| cience room 218 | HSE-196 | Faucet #2 - See Map 218 | 28.2 | POST |
| cience room 218 | HSE-197 | Faucet #3 - See Map 218 | 20.4 | POST |
| cience room 218 | HSE-198A | Faucet #4 - See Map 218 | 10.5 | |
| cience room 218 | HSE-198B | Faucet #5 - See Map 218 | 27.2 | POST |
| cience room 218 | HSE-199 | Faucet #6 - See Map 218 | 7.1 | |
| cience room 218 | HSE-200 | Faucet #7- See Map 218 | 29.4 | POST |
| cience room 218 | HSE-201 | Faucet #8 - See Map 218 - Not working | Х | |
| 19 Prep Room between 218/220 | HSE-202 | 1 -Faucet on room 218 side | 77.8 | POST |
| 19 Prep Room between 218/220 | HSE-203 | 1- Faucet on room 220 side | 22.6 | POST |
| cience room 220 | HSE-204 | Faucet #1 - See Map 220 | 38.9 | POST |
| cience room 220 | HSE-205 | Faucet #2 - See Map 220 | 14.7 | |
| cience room 220 | HSE-206 | Faucet #3 - See Map 220 | 16.0 | POST |
| cience room 220 | HSE-207 | Faucet #4 - See Map 220 | 28.3 | POST |
| cience room 220 | HSE-208 | Faucet #5 - See Map 220 | 21.6 | POST |
| | HSE-209 | Faucet #6 - See Map 220 | 30.7 | POST |
| cience room 220 | HSE-210 | Faucet #7 - See Map 220 - Work Station | 15.7 | POST |
| BOYS BATHROOM BY B 222 - J 16 | | LEFT 1 | 1.3 | |
| | cience room 215 cience room 217 cience room 217 cience room 217 cience room 217 cience room 218 cience room 220 | HSE-188M HSE-188M HSE-188N HSE-188N HSE-188N HSE-188N HSE-188P HSE-188P HSE-188P HSE-188P HSE-188P HSE-188P HSE-188P HSE-188P HSE-189 HSE-190 HSE-191 HSE-191 HSE-191 HSE-192A HSE-192A HSE-192B HSE-192B HSE-192B HSE-192B HSE-193 HSE-193 HSE-194 HSE-194 HSE-195 HSE-195 HSE-196 HSE-196 HSE-197 HSE-198A HSE-198A HSE-198A HSE-198A HSE-198A HSE-198A HSE-198A HSE-198A HSE-198B HSE-198A HSE-199 HSE-200 HSE- | HSE-188M (see map) Science 215 HSE-188M (see map) Science 215 HSE-188N (see map) Science 215 HSE-188P HSE-188P HSE-189N HSE-189N HSE-189N HSE-191 HSE-192N HSE-192N HSE-192N HSE-192N HSE-192N HSE-192N HSE-192N HSE-193N HSE-193N HSE-193N HSE-193N HSE-193N HSE-194 HSE-194 HSE-195 HS | HSE-188M (see map) Science 215 47.7 |

| Sink Faucet | BOYS BATHROOM BY B 222 - J 16 | HSE-212 | MIDDLE 2 | 3.7 | |
|---------------------------|---|-----------|---|--------|---------|
| Sink Faucet | BOYS BATHROOM BY B 222 - J 16 | HSE-213 | RIGHT SIDE 3 | 4.4 | |
| Sink Faucet | Girls Room by B 227 - J-17 | HSE-214 | Starting closest to door Faucet #1 | 4.4 | |
| Sink Faucet | Girls Room by B 227 - J-17 | HSE-215 | Starting closest to door Faucet #2 | 2.7 | |
| Sink Faucet | Girls Room by B 227 - J-17 | HSE-216 | Starting closest to door Faucet #3 | 3.1 | |
| Sink Faucet | Girls Room by B 227 - J-17 | HSE-217 | Faucet #4 - Furthest from door | 2.1 | |
| Sink Faucet | Room 237 | HSE-218 | Faucet closest to door | 665.0 | REMOVED |
| Sink Faucet | Room 237 | HSE-219 | Faucet Farthest from door | 1590.0 | REMOVED |
| Sink Faucet | Room 238 | HSE-219A | Room 238 Right | 103.0 | REMOVED |
| Sink Faucet | Ladies Faculty Bathroom by 237 | HSE-220 | Faucet #1 - Looking at sink - Right side | 0.34 | |
| Sink Faucet | Ladies Faculty Bathroom by 237 | HSE-221 | Faucet #1 - Looking at sink - Right side | 0.91 | |
| Sink Faucet | Men's faculty bathroom by room 237 | HSE-222 | Facing sinks to the left sink#1 | 1.4 | |
| Sink Faucet | Men's faculty bathroom by room 237 | HSE-223 | Facing sinks to the right Sink#2 | 1.3 | |
| Sink Faucet | Room 247 | HSE-224 | 1-Faucet | 27.2 | REMOVED |
| Sink Faucet | Room 250 | HSE-225 | 1-Faucet | 150.0 | REMOVED |
| Sink Faucet | Room 251 | HSE-226 | 1-Faucet | 20.4 | REMOVED |
| Sink Faucet | Room 253 | HSE-227 | 1-Faucet | 73.1 | REMOVED |
| Sink Faucet | Room 257 | HSE-228 | Facing sink to the left #1 | 26.7 | <1 |
| Sink Faucet | Room 257 | HSE-229 | Facing sink to the right #2 | 5.9 | |
| Sink Faucet | Room 258 | HSE-230 | 1-Faucet | 11.6 | |
| Sink Faucet | Men's room across from 261 - J15 | HSE-231 | Facing sinks to the left sink#2- Not in Srvc. | Х | |
| Sink Faucet | Ladies room across from 261 - J15 | HSE-232 | Facing sinks to the Right Sink#2 - Not in Srvc. | Х | |
| Sink Faucet | Handi Cap | HSE-233 | Across from 258/259 | 8.7 | |
| Drinking Fountains | | | | | |
| Drinking Fountain | Cafateria - North end (towards dock) | HSE-DF-01 | | <0.10 | |
| Drinking Fountain | Cafateria - Sount end (near main lobby) | HSE-DF-02 | | <0.10 | |
| Drinking Fountain | Outside 107 | HSE-DF-03 | | 2.4 | |
| Drinking Fountain | Outside 119 | HSE-DF-04 | | 0.75 | |
| Drinking Fountain | Outside South Faculty Room | HSE-DF-05 | | 0.57 | |
| Drinking Fountain | Near Refuge Room (dock) | HSE-DF-06 | | 0.24 | |
| | · · · · · · · · · · · · · · · · · · · | | | | |

| Drinking Fountain | Across - Boys Gang Bathroom - Front Hall | HSE-DF-07 | | 0.59 | |
|-------------------|--|-------------|----------------------------|------|--|
| Drinking Fountain | Outside Boys Gang Bathroom - West Wing | HSE-DF-08 | Left Fountain | 2.3 | |
| Drinking Fountain | Outside Boys Gang Bathroom - West Wing | HSE-DF-09 | Right Fountain | 1.8 | |
| Drinking Fountain | Outside 141 - West Wing | HSE-DF-10 | | 3.1 | |
| Drinking Fountain | Outside 141 - West Wing | HSE-DF-10-A | | 3 | |
| Drinking Fountain | Outside Gym J-Rm West Wing | HSE-DF-12 | | 0.24 | |
| Drinking Fountain | Boys Locker Rm - New Gym | HSE-DF-13 | | 0.63 | |
| Drinking Fountain | Girls Locker Rm - New Gym | HSE-DF-14 | Not in Service | Х | |
| Drinking Fountain | Outside Gym Storage near Exit 14 | HSE-DF-15 | | 0.51 | |
| Drinking Fountain | Outside Girls Gang Bathroom - West Wing | HSE-DF-16 | Left Fountain | 5.8 | |
| Drinking Fountain | Outside Girls Gang Bathroom - West Wing | HSE-DF-17 | Right Fountain | 6.5 | |
| Drinking Fountain | Girls Rm near 207 | HSE-DF-18 | | 0.54 | |
| Drinking Fountain | Outside 223 | HSE-DF-19 | | 1.3 | |
| Drinking Fountain | Outside 227 | HSE-DF-20 | | 1.3 | |
| Drinking Fountain | Outside Room C102 | HSE-DF-21 | Fountain Outside Room C102 | 0.52 | |
| Drinking Fountain | Boys Locker Rm | HSE-DF-22 | Boys Locker Rm Fountain | 1.5 | |
| Drinking Fountain | Grils Locker Rm. | HSE-DF-23 | | 1.9 | |
| Drinking Fountain | Boys Locker Rm. | HSE-DF-24 | | 0.72 | |
| Drinking Fountain | Grils Gang BR - New | HSE-DF-25 | Left Fountain | 0.14 | |
| Drinking Fountain | Grils Locker rm - New | HSE-DF-26 | Right Fountain | 0.74 | |

Per the Department of Health: Sink faucets that tested higher then the 15ppb action level that are located in lab classrooms are not required to be changed out as long as schools have strict internal control measures in place (i.e. SOP prohibiting eating and drinking in scientific classrooms) together with appropriate signage and supervision in these classrooms, these measures can be considered permanent remedies.