

SHEHENDEHOWA CENTRAL SCHHOL DISTRICT SAMPLING LOCATION / ID NUMBER

BUILDING: Shatekon Elementary DATE: 2/17/17

CUSTODAIN: _____ CONTACT #: _____

BUILDING ADDRESS: 35 Maxwell Drive, Clifton Park NY 12065 # OF SAMPLES: 100

<u>OUTLET TYPE</u>	<u>LOCATION</u>	<u>ID NUMBER</u>	<u>NOTES</u>	<u>RESULTS</u>
sink	Shatekon cafeteria rm 311	SHA-01	across from storage 304	1.7
sink	faculty rm313	SHA-02	across from cafeteria	1.2
sink	custodial closet	SHA-03	Locked and secure - Posted non-potable	X
sink #1	Boys bathroom	SHA-04	by store room 304	1.2
sink #2	Boys bathroom	SHA-05	by store room 304	< 1.0
sink #1	Girls bathroom	SHA-06	by faculty rm 313	1.0
sink #2	Girls bathroom	SHA-07	by faculty rm313	< 1.0
fountain #1	hallway	SHA-08	by boys rm. m fountain #1 to the left facing them	< 1.0
fountain #2	hallway	SHA-09	by boys r. fountain #2 to the right facing them	< 1.0
sink	Staff bathroom	SHA-10	closest to girls bathroom	< 1.0
sink	staff bathroom	SHA-11	closest to rm 315	1.7
sink	custodial closet	SHA-12	Locked and secure - Posted non-potable	X
sink	rm312	SHA-13		1.7
fountain	rm312	SHA-14		< 1.0
sink	rm 315	SHA-15		3.6
fountain	rm315	SHA-16		< 1.0
sink	rm 317	SHA-17		1.3
fountain	rm 317	SHA-18		< 1.0
sink	rm 314	SHA-19		< 1.0
fountain	rm 314	SHA-20		< 1.0
sink	rm 319	SHA-21		2.0
fountain	rm 319	SHA-22		< 1.0
sink	rm 321	SHA-23		1.1

fountain	rm321	SHA-24		< 1.0
sink	rm 316	SHA-25		< 1.0
fountain	rm316	SHA-26		< 1.0
fountain #1	hall way	SHA-27	hall by exit 6 facing fountains to the left is #1	< 1.0
fountain #2	hallway	SHA-28	hall by exit 6 facing fountains to the left is #2	< 1.0
bath sink	rm 322	SHA-29		3.3
sink	custodial closet	SHA-30	between rm 321 and 325	X
sink	rm 325	SHA-31		2.9
fountain	rm325	SHA-32		< 1.0
sink	rm 324	SHA-33		1.2
fountain	rm 324	SHA-34		< 1.0
sink	rm 326	SHA-35		1.1
fountain	rm 326	SHA-36		<1.0
sink	rm 327	SHA-37		1.4
fountain	rm 327	SHA-38		< 1.0
sink	rm 328	SHA-39		1.1
fountain	rm 328	SHA-40		< 1.0
sink	rm 329	SHA-41		< 1.0
fountain	rm 329	SHA-42		< 1.0
sink	rm 330	SHA-43		< 1.0
fountain	rm 330	SHA-44		< 1.0
sink	rm 331	SHA-45		1.8
fountain	rm 331	SHA-46		< 1.0
sink	rm 332	SHA-47		1.1
fountain	rm 332	SHA-48		< 1.0
sink #1	nurse rm 333	SHA-49	sink by window is sink #1	< 1.0
Sink #2	nurse rm 333	SHA-50	Bathroom sink is sink #2	< 1.0
sink	rm 337	SHA-51	staff mail / copy room	3.0
sink	conference room rm335	SHA-52	next to copy room	6.5
sink faucet #1	girls bathroom	SHA-53	by library facing sink faucet #1 to left	< 1.0

sink faucet #2	girls bathroom	SHA-54	by library facing sink faucet #2 to right	< 1.0
sink	library	SHA-55		3.5
sink faucet #1	boys bathroom	SHA-56	by library facing sink faucet to left is #1	< 1.0
sink faucet #2	boys bathroom	SHA-57	by library facing sink faucet to left is #2	< 1.0
sink	main office	SHA-58	kitchen area	< 1.0
sink	main office	SHA-59	bathroom	< 1.0
sink #1	rm 342	SHA-60	kitchen sink	< 1.0
sink #2	rm 342	SHA-61	bathroom sink	2.1
sink	rm 344	SHA-62		1.2
fountain	rm 344	SHA-63		< 1.0
sink	rm 345	SHA-64		2.1
fountain	rm 345	SHA-65		< 1.0
sink	rm 347	SHA-66		1.7
fountain	rm 347	SHA-67		< 1.0
sink	rm 346	SHA-68		< 1.0
fountain	rm 346	SHA-69		< 1.0
sink	rm 348	SHA-70		1.7
fountain	rm 348	SHA-71		< 1.0
sink	rm 349	SHA-72		1.7
fountain	rm 349	SHA-73		< 1.0
sink	rm 351	SHA-74		2.2
fountain	rm 351	SHA-75		< 1.0
sink	rm 350	SHA-76		1.7
fountain	rm 350	SHA-77		< 1.0
sink	rm 352	SHA-78		1.2
fountain	rm 352	SHA-79		< 1.0
sink	custodial closet	SHA-80	Locked and secure - Posted non-potable	X
kitchen sink	rm 354	SHA-81		< 1.0
bathroom sink	rm 354	SHA-82		< 1.0
fountain #1	hallway	SHA-83	by rm 354 facing fountain to the left is #1	< 1.0

fountain #2	hallway	SHA-84	by rm 354 facing fountain to the right is #2	< 1.0
sink	rm 355	SHA-85		4.2
fountain	rm 355	SHA-86		< 1.0
sink	rm 357	SHA-87		1.7
fountain	rm 357	SHA-88		< 1.0
sink #1	art rm 358	SHA-89	side wall to the left sink #1	<1.0
sink #2	art rm 358	SHA-90	side wall in the middle sink #2	< 1.0
sink #3	art rm 358	SHA-91	side wall to the right sink #3	1.1
sink #4	art rm 358	SHA-92	sink close to entrance to room sink #4	< 1.0
sink	rm 360	SHA-93		2.4
sink faucet #1	boys bathroom	SHA-94	by gym entrance facing sink faucet to left is #1	< 1.0
sink faucet #2	boys bathroom	SHA-95	by gym entrance facing sink faucet to left is #2	< 1.0
sink faucet #1	girls bathroom	SHA-96	by gym entrance facing sink faucet to left is #1	< 1.0
sink faucet #2	girls bathroom	SHA-97	by gym entrance facing sink faucet to right is #2	< 1.0
sink	coach office rm 361	SHA-98	bathroom	< 1.0
fountain #1	gym entrance	SHA-99	facing fountain to the left is fountain #1	< 1.0
fountain #2	gym entrance	SHA-100	facing fountain to the left is fountain #2	< 1.0