

**SHEHENDEHOWA CENTRAL SCHOL DISTRICT SAMPLING LOCATION / ID NUMBER**

|                   |                                     |               |         |
|-------------------|-------------------------------------|---------------|---------|
| BUILDING:         | Skano Elementary                    | DATE:         | 2/17/17 |
| CUSTODAIN:        |                                     | CONTACT #:    |         |
| BUILDING ADDRESS: | 970 Route 146 Clifton Park NY 12065 | # OF SAMPLES: | 84      |

| <u>OUTLET TYPE</u>          | <u>LOCATION</u>        | <u>ID NUMBER</u> | <u>NOTES</u>                             | <u>RESULTS</u> | <u>RETEST</u> |
|-----------------------------|------------------------|------------------|--|----------------|---------------|
| Rubber hose faucet          | Dock                   | SKA-1            |  | 2.2            |               |
| Sink faucet                 | Faculty room           | SKA-2            | Next to exit 7                           | < 1.0          |               |
| Sink faucet                 | Music room             | SKA-3            | Small room on the right off the music rm | 5.2            |               |
| Classroom sink faucet       | Room 26                | SKA-4            |  | 6.7            |               |
| Classroom drinking fountain | Room 26                | SKA-5            |  | 13.0           |               |
| Classroom sink faucet       | Room 25                | SKA-6            |  | 3.8            |               |
| Classroom drinking fountain | Room 25                | SKA-7            |  | 9.8            |               |
| Classroom sink faucet       | Room 24                | SKA-8            |  | 4.3            |               |
| Classroom drinking fountain | Room 24                | SKA-9            |  | 7.7            |               |
| Classroom sink faucet       | Room 23                | SKA-10           |  | 6.0            |               |
| Classroom drinking fountain | Room 23                | SKA-11           |  | 12.0           |               |
| Classroom sink faucet       | Room 22                | SKA-12           |  | 8.5            |               |
| Classroom drinking fountain | Room 22                | SKA-13           |  | 7.9            |               |
| Classroom sink faucet       | Room 21                | SKA-14           |  | 4.3            |               |
| Classroom drinking fountain | Room 21                | SKA-15           |  | 5.2            |               |
| Classroom sink faucet       | Room 20                | SKA-16           |  | 8.4            |               |
| Classroom drinking fountain | Room 20                | SKA-17           |  | 23.0           | <1            |
| Classroom sink faucet       | Room 70                | SKA-18           |  | 3.0            |               |
| Classroom sink faucet       | Room 71                | SKA-19           |  | 1.5            |               |
| Classroom drinking fountain | Room 71                | SKA-20           |  | < 1.0          |               |
| Restroom sink faucet        | Boys restroom room 71  | SKA-21           | Between rooms 71 and 72                  | 1.6            |               |
| Restroom sink faucet        | Girls restroom Room 71 | SKA-22           | Between Rooms 71 and 72                  | 1.6            |               |
| Classroom sink faucet       | Room 72                | SKA-23           |  | 4.6            |               |

|                             |                        |        |                         |       |     |
|-----------------------------|------------------------|--------|-------------------------|-------|-----|
| Classroom drinking fountain | Room 72                | SKA-24 |                         | < 1.0 |     |
| Restroom sink faucet        | Boys restroom Room 72  | SKA-25 | Between Rooms 72 and 73 | 1.9   |     |
| Restroom sink faucet        | Girls restroom Room 72 | SKA-26 | Between Rooms 72 and 73 | 3.0   |     |
| Classroom sink faucet       | Room 73                | SKA-27 |                         | 1.2   |     |
| Classroom drinking fountain | Room 73                | SKA-28 |                         | < 1.0 |     |
| Classroom sink faucet       | Room 19                | SKA-29 |                         | 7.4   |     |
| Classroom drinking fountain | Room 19                | SKA-30 | Out of Service          | X     |     |
| Classroom sink faucet       | Room 18                | SKA-31 |                         | 8.4   |     |
| Classroom drinking fountain | Room 18                | SKA-32 |                         | 9.5   |     |
| Classroom sink faucet       | Room 17                | SKA-33 |                         | 3.1   |     |
| Classroom drinking fountain | Room 17                | SKA-34 |                         | 6.6   |     |
| Classroom sink faucet       | Room 16                | SKA-35 |                         | 5.7   |     |
| Classroom drinking fountain | Room 16                | SKA-36 | Out of Service          | X     |     |
| Classroom sink faucet       | Room 15                | SKA-37 |                         | 5.5   |     |
| Classroom drinking fountain | Room 15                | SKA-38 |                         | 6.3   |     |
| Drinking fountain           | Lobby                  | SKA-39 |                         | < 1.0 |     |
| Room sink faucet            | Counselors office      | SKA-40 |                         | 17.0  | <1  |
| Restroom sink faucet        | Health office          | SKA-41 |                         | 18.0  | <1  |
| sink faucet                 | Health office          | SKA-42 | Rear room with beds     | 11.0  |     |
| Classroom sink faucet       | room 14                | SKA-43 |                         | 8.3   |     |
| Classroom drinking fountain | Room 14                | SKA-44 |                         | 16.0  | 3.0 |
| Classroom sink faucet       | Room 13                | SKA-45 |                         | 2.9   |     |
| Classroom drinking fountain | Room 13                | SKA-46 |                         | 15.0  |     |
| Classroom sink faucet       | Room 12                | SKA-47 |                         | 6.0   |     |
| Classroom drinking fountain | Room 12                | SKA-48 |                         | 15.0  |     |
| Classroom sink faucet       | Room 11                | SKA-49 |                         | 5.6   |     |
| Classroom drinking fountain | Room 11                | SKA-50 |                         | 14.0  |     |
| Classroom sink faucet       | Room 10                | SKA-51 |                         | 4.9   |     |
| Classroom drinking fountain | Room 10                | SKA-52 |                         | 14.0  |     |
| Classroom sink faucet       | Room 9                 | SKA-53 |                         | 4.3   |     |

|                             |                        |        |   |      |      |
|-----------------------------|------------------------|--------|---|------|------|
| Classroom drinking fountain | Room 9                 | SKA-54 |   | 15.0 |      |
| Classroom sink faucet       | Room 8                 | SKA-55 |   | 5.6  |      |
| Classroom drinking fountain | Room 8                 | SKA-56 |   | 9.5  |      |
| Classroom bathroom sink     | Room 8                 | SKA-57 |   | 5.0  |      |
| Classroom bathroom sink     | Room 7                 | SKA-58 |   | 14.0 |      |
| Classroom drinking fountain | Room 7                 | SKA-59 |   | 10.0 |      |
| Classroom sink faucet       | Room 7                 | SKA-60 |   | 6.4  |      |
| Restroom sink faucet #1     | Men's staff restroom   | SKA-61 | By exit 2 (left-hand sink)              | 17.0 | <1   |
| Restroom sink faucet #2     | Men's staff restroom   | SKA-62 | By exit 2 (right-hand sink)             | 9.7  |      |
| Restroom sink faucet #1     | Women's staff restroom | SKA-63 | By exit 2 (left-hand sink)              | 30.0 | <1   |
| Restroom sink faucet #2     | Women's staff restroom | SKA-64 | By exit 2 (right-hand sink)             | 40.0 | 10.0 |
| Classroom sink faucet       | Room 6                 | SKA-65 |   | 5.5  |      |
| Classroom drinking fountain | Room 6                 | SKA-66 |   | 6.0  |      |
| Classroom sink faucet       | Room 5                 | SKA-67 |   | 7.2  |      |
| Classroom drinking fountain | Room 5                 | SKA-68 | Out of Service                          | X    |      |
| Classroom sink faucet       | Room 4                 | SKA-69 |   | 7.7  |      |
| Classroom drinking fountain | Room 4                 | SKA-70 | Out of Service                          | X    |      |
| Classroom sink faucet       | Room 3                 | SKA-71 |   | 6.3  |      |
| Classroom drinking fountain | Room 3                 | SKA-72 | Out of Service                          | X    |      |
| Classroom sink faucet       | Room 2 (computer rm)   | SKA-73 |   | 7.0  |      |
| Classroom drinking fountain | Room 2 (computer rm)   | SKA-74 |   | 12.0 |      |
| Classroom sink faucet       | Room 1                 | SKA-75 |   | 4.8  |      |
| Classroom drinking fountain | Room 1                 | SKA-76 |   | 17.0 | 11.0 |
| Restroom sink faucet        | Main office            | SKA-77 |   | 7.1  |      |
| Room sink faucet            | Library                | SKA-78 | Small office of Library                 | 23.0 | <1   |
| Restroom sink faucet        | Phys Ed office         | SKA-79 |   | 67.0 | 1.0  |
| Restroom sink faucet #1     | Boys gang restroom     | SKA-80 | Across from copy room (left-hand sink)  | 3.3  |      |
| Restroom sink faucet #2     | Boys gang restroom     | SKA-81 | Across from copy room (right-hand sink) | 3.2  |      |
| Restroom sink faucet #1     | Girls gang restroom    | SKA-82 | Across from copy room (left-hand sink)  | 5.4  |      |
| Restroom sink faucet #2     | Girls gang restroom    | SKA-83 | Across from copy room (right-hand sink) | 2.6  |      |

|                   |           |        |  |     |  |
|-------------------|-----------|--------|--|-----|--|
| Drinking fountain | Cafeteria | SKA-84 |  | 5.2 |  |
|-------------------|-----------|--------|--|-----|--|

**EXAMPLES:**

**Outlet Type:** Sink Faucet, drinking Fountain, Sink Bubbler, Ice Machine, Plumbed Coffee maker

**Location:** Classroom #, Kitchen, Boys restroom, Girls restroom, Lobby, Nurses office, Hall/Near Room, Break room